



# AMERESCO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeff Teagarden  
Dore & Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker - Phase IV  
Engineering Building (Building # 92)

Project No. 11.2466

Date Inspected: December 21, 2010

Analysis/Method: Asbestos - Bulk Material / Polarized Light Microscopy (EPA 600/M4-82-020)

\*\*\*\*\*


| SAMPLE ID | MATRIX | LOCATION and DESCRIPTION                               | <u>ASBESTOS</u> | <u>NON-ASBESTOS</u> |
|-----------|--------|--|-----------------|---------------------|
| 92-01C    | Misc   | Second Floor - East Side of Building<br>Window Glazing | ND              | 99-100% Binder      |

ND = None Detected (Asbestos not detected above the detection limit of PLM Methodology.)

Analyzed by: SAC

Ref Number: 293994

Inspector:

  
 Jeffrey Rugg  
 IDEM License # 194722076  
 Expiration Date: 09/24/2011

BUR = Built-up Roofing  
 TSI = Thermal System Insulation  
 Surf = Surfacing Material  
 Misc = Miscellaneous Material  
 Other = Binder Constituents

