



# AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeff Teagarden  
Dore & Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker - Phase IV  
Foundry Building (Building # 85)

Project No. 11.2558

Date Inspected: February 23 , 2011

Analysis/Method: Asbestos - Bulk Material / Polarized Light Microscopy (EPA 600/M4-82-020)

\*\*\*\*\*


SAMPLE ID	MATRIX	LOCATION and DESCRIPTION	ASBESTOS	NON-ASBESTOS
85-09A	Misc	Built-up roofing-North	Chrysotile 5-10%	90-95% Binder
85-09B	Misc	Built-up roofing-Northwest	Chrysotile 5-10%	90-95% Binder
85-09C	Misc	Built-up roofing-West	Chrysotile 5-10%	90-95% Binder
85-07D	Misc	Window glazing compound (pink) North Wall 2 <sup>nd</sup> Floor	ND	99-100% Binder
85-07E	Misc	Window glazing compound (gray) East	Chrysotile 1-5%	95-99% Binder
85-07F	Misc	Window glazing compound (gray) Northwest (very thick glazing)	ND	99-100% Binder
85-07G	Misc	Window glazing compound From fiberglass panels (west)	Chrysotile 1-5%	95-99% Binder

ND = None Detected (Asbestos not detected above the detection limit of PLM Methodology.)

Analyzed by: SAC

Ref Number: 293994

Inspector:

  
 John Blosky  
 IDEM License # 198701061  
 Expiration Date: 12/04/2011

BUR = Built-up Roofing  
 TSI = Thermal System Insulation  
 Surf = Surfacing Material  
 Misc = Miscellaneous Material  
 Other = Binder Constituents





# AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeffrey C. Teagarden  
Dore and Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker Phase IV  
Foundry - Building # 85

Project No. 11.2558

Analysis: Point Count Asbestos - Bulk Material

Method: Polarized Light Method: EPA 600/M4-82-020  
Quantitation using 400 Point Count Procedure

\*\*\*\*\*


SAMPLE ID	MATRIX	LOCATION and DESCRIPTION	Points on Asbestos	Points on Non-Asbestos	% Asbestos
85-09A	BUR	Foundry (Building # 85) North Side Built-up Roofing	30	370	7.50
85-09B	BUR	Foundry (Building # 85) Northwest Side Built-up Roofing	27	373	6.75
85-09C	BUR	Foundry (Building # 85) West Side Built-up Roofing	29	371	7.25
85-07E	Misc	Foundry (Building # 85) East Side Window Glazing Compound - Gray	9	391	2.25
85-07G	Misc	Foundry (Building # 85) West Side - Fiberglass Panels Window Glazing Compound	11	389	2.75

ND=None Detected (Asbestos not detected above the detection limit of PLM Methodology.)

Analyzed by: SAC

Ref Number: 294247

Inspector: \_\_\_\_\_

  
John Blosky  
DEM License # 198701061  
Expiration Date: 12/04/2011

BUR = Built-up Roofing  
TSI = Thermal System Insulation  
Surf = Surfacing Material  
Misc = Miscellaneous Material  
Other = Binder Constituents

