



AMERESCO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT

FINAL INSPECTION CHECKLIST ASBESTOS REMOVAL

Date: 2/28/11 Project Name: STUDEBAKER DEMO
 Contractor: DORF & ASSOCIATES Location: FOUNDRY BLDG.
 Supervisor: DAN DORF JEFF TEAGARDEN MEET/BORDER ROOM.

THIS FORM SHALL BE COMPLETED IN ACCORDANCE WITH THE OSHA REGULATION TITLED: STANDARDS AND INTERPRETATIONS, 1926.58, APPENDIX F.

CHECKLIST:

RESIDUAL DUST ON:

	YES	NO
Floor	_____	<u>X</u>
Horizontal Surfaces	_____	<u>X</u>
Vertical Surfaces	_____	<u>X</u>
Ventilation Equipment	_____	<u>X</u>
Pipes	_____	<u>X</u>
Ducts	_____	<u>X</u>
Registers	_____	<u>X</u>
Lights	_____	<u>X</u>
Other	_____	<u>X</u>

Description: _____

FIELD NOTES:

Record any problems encountered here:

NONE

FINAL SAMPLING:

	YES	NO	N/A
Final HEPA vacuum after removal	_____	_____	<u>X</u>
Final wet clean (18hr. wait after HEPA vac.)	_____	_____	<u>X</u>
Final wipe sample (18 hr. wait after wet clean)	_____	_____	<u>X</u>

FINAL SAMPLING RESULTS (VERBAL NOTIFICATION): _____

[Signature] Ameresco Engineering
 204 EAST JEFFERSON • VALPARAISO, IN 46383 • OFFICE (219) 464-0460 • FAX (219) 464-0464
 Contractor [Signature] Other 2/28/11
 Copyright © 1999





AMERESCO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT

Certificate of Completion

Asbestos Abatement

Client Name: DORE & ASSOCIATES CONTRACTING
 Location: STUDE BAKER PHASE IV FOUNDRY BLDG.
 Description: REMOVAL OF ACM'S FROM MECH./BOILER ROOM

Based on the results of: continuous on-site work practice and engineering controls, daily area and ambient monitoring, final visual inspection and clearance air sample testing and analysis for the above listed project:

The project area and adjacent staging and holding areas are certified clean and free of all visible suspect asbestos debris, therefore, fit for re-occupancy. The adjacent areas, buildings, and the surrounding environment were unaffected by abatement activities, and all ambient air sampling tests remained within acceptable limits.

This form must be completed pursuant to the Indiana Department of Environmental Management's Air Pollution Control Board's Final Rule 326 IAC 14-10-4 (10).

Nicholas Zuniga
 Contractor's Supervisor

[Signature]
 Ameresco Engineering

Nicholas Zuniga
 Printed Name

JAMES C. KURTZ
 Printed Name

191931082
 License Number / Expiration Date

2/28/11
 Date

Copyright © 1998 Ameresco, Inc.