

M-0005

FROM : DEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:20AM P2

SUNPRO

24 Hour Phone 800-488-0910

Fax 574-262-9780

www.sunproservices.com

RECEIVED
12/14/2005**UST CLOSURE REPORT****BERRETH OIL COMPANY PROPERTY SITE
134 W. MISHAWAKA AVENUE
MISHAWAKA IN****PERMANENT CLOSURE OF FOUR (4) UNDERGROUND STORAGE TANKS
(2) 2,000 GALLON GASOLINE UST SYSTEMS
(2) 8,000 GALLON GASOLINE UST SYSTEMS****APRIL 24, 2004****Michlana Regional Office: 23843 CR 6, Unit B-16-1A • Elkhart, Indiana 46514-9691
Corporate Office: 7392 Whipple Ave., NW • North Canton, Ohio 44720-7140**

CONTENTS OF UST CLOSURE REPORT

1. COPY OF STATE OF INDIANA AND IFCI CERTIFICATION FOR PERMANENT CLOSURE OF UNDERGROUND STORAGE TANKS.
2. SIGNATURE WAIVER AUTHORIZATION
3. NOTIFICATION FOR UNDERGROUND STORAGE TANKS - IDEM FORM 45223 - A REQUEST FOR CLOSURE OF UST DATED MARCH 4, 2004
4. 30-DAY NOTIFICATION OF UST CLOSURE AS SUBMITTED TO OFFICE OF STATE FIRE MARSHAL AND MISHAWAKA FIRE DEPARTMENT ON MARCH 4, 2004
5. UST CLOSURE REPORT DATA
6. SITE PHOTOGRAPHS (20)
7. SITE DIAGRAMS (11)
8. CLEARANCE SOIL SAMPLING ANALYTICAL DATA AND CHAIN-OF-CUSTODY DOCUMENTATION
9. CERTIFICATION RE: DISPOSAL OF REMOVED UNDERGROUND STORAGE TANK
10. CERTIFICATION DISPOSAL OF REMOVED PRODUCT-SLUDGE-RESIDUAL MATERIALS


STATE OF INDIANA UNDERGROUND STORAGE TANK CERTIFICATION

This Certificate is issued to
JOHN BAMBER
Designating Satisfactory Completion of the
State-Approved Examination for Certification as

Date of Issue 04/15/2003	Expiration date 04/15/2008	Certification number UC20014416
State Fire Marshal <i>M. Tracy Britton</i>		


State Form 45072 (R/1-93)

State of Indiana Underground Storage Tank Certification

Name JOHN BAMBER	
Certified as: DECOMMISSIONING	
Certification number UC20014416	
Date of Issue 04/15/2003	
Expiration date 04/15/2008	

EMPLOYER'S COPY State Form 45072 (R/1-93)

State of Indiana Underground Storage Tank Certification

Name JOHN BAMBER	
Certified as: DECOMMISSIONING	
Certification number UC20014416	
Date of issue 04/15/2003	
Expiration date 04/15/2008	

WALLET CARD State Form 45072 (R/1-93)

Detach this wallet card ↑ and carry with you for your personal record.

← Detach this 3 x 6 card

INTERNATIONAL CODE COUNCIL

JOHN L BAMBER

The International Code Council attests that the individual named on this certificate has satisfactorily demonstrated knowledge as required by the International Code Council by successfully completing the prescribed written examination based on codes and standards then in effect, and is hereby issued this certification as:

UST DECOMMISSIONING

given this day of April 15, 2003

1138579-U2

Certificate Number



Paul E Myers
President, ICC Board of Directors

JOHN L BAMBER
UNDERGROUND STORAGE TANK
DECOMMISSIONING



The individual named hereon is CERTIFIED in the category shown, having been so certified pursuant to successful completion of the prescribed written examination.

Expiration date: April 15, 2005

No. 1138579-112



Not valid unless signed by certificate holder.
ICC certification attests to competent knowledge of codes and standards.



INTERNATIONAL
CODE COUNCIL®

FROM : DEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:23AM P7

SUNPRO

24 Hour Phone 800-488-0910
Fax 574-262-9780
www.sunproservices.com

MARCH 4, 2004

MS. NAWAL HOPKINS
INDIANA DEPARTMENT
OF ENVIRONMENTAL MANAGEMENT
UNDERGROUND STORAGE TANK BRANCH
POST OFFICE BOX 7015
100 N. SENATE AVENUE ROOM -1255
INDIANAPOLIS IN 46207-7015

VIA CERTIFIED MAIL 7003 1010 0005 5019 5829

RE: **30-DAY NOTIFICATION REQUEST FOR CLOSURE OF UST**
BERRETH OIL COMPANY PROPERTY SITE
134 W. MISHAWAKA AVENUE MISHAWAKA IN


Dear Ms. Hopkins:

To allow for permanent closure of two (3), 3,000 gallon gasoline underground storage tank systems at the above referenced facility, we are herewith transmitting the following documents on behalf of our client:

1. CLIENT SIGNATURE AUTHORIZATION DOCUMENT
2. NOTIFICATION FOR UNDERGROUND STORAGE TANKS, IDEM STATE FORM 45223 - REQUEST FOR CLOSURE

Please contact me if you have any questions regarding this matter or require additional information.

Sincerely,



John Bamber
SUNPRO Inc.,

Michiana Regional Office: 23843 CR 6, Unit B-16-1A • Elkhart, Indiana 46514-9691
Corporate Office: 7392 Whipple Ave., NW • North Canton, Ohio 44720-7140

NOV-08-2005 09:24

5742341615

98%

P.07

STATE FORM 45229 (REV. 2/99)

NOTIFICATION FOR UNDERGROUND STORAGE TANKS

RETURN COMPLETED FORMS TO: Indiana Department of Environmental Management
Office of Environmental Response, UST Branch
100 North Senate Avenue
P.O. Box 7015
Indianapolis, Indiana 46207-7015
UST: (317) 308-3064 LUST: (317) 308-3088



Facility ID Number	
Owner ID Number	
Federal ID Number	
EPA ID Number	

A Notification is required by Federal and State laws for all storage tanks that are operational or have been used to store regulated substances since January 1, 1974. The information requested is required by Section 9002 of the Resource Conservation and Recovery Act (RCRA) and Indiana Code 329 IAC 9, as amended. Specific detailed instructions for the completion of this form may be found in the Underground Storage Tank Branch Guidance Manual (Rev. 11/95), on page 4 of this form, or by contacting the UST Branch at the above address.

TYPE OF NOTIFICATION

THIS NOTIFICATION FORM PROVIDES INFORMATION FOR (CHECK ALL THAT APPLY):

<input type="radio"/> A NEW FACILITY	<input type="radio"/> A CHANGE OF OWNERSHIP	<input checked="" type="radio"/> A TEMPORARY CLOSURE
<input type="radio"/> A NEW OWNER	<input type="radio"/> A SYSTEM UPGRADE	<input type="radio"/> A REQUEST FOR CLOSURE
<input checked="" type="radio"/> A NEW TANK	<input type="radio"/> AN ADDRESS CHANGE	<input type="radio"/> A PERMANENT CLOSURE
<input type="radio"/> A NEW OPERATOR	<input type="radio"/> OTHER	<input type="checkbox"/> WITH CLOSURE REPORT

B OWNER OF TANKS

OWNER NAME	BERRETH OIL COMPANY
MAILING ADDRESS	1301 W. SIXTH STREET
CITY	MISHAWAKA IN 46544
STATE	IN
ZIP CODE	46544
TELEPHONE NUMBER	574-255-4077

OPERATOR OF FACILITY

OPERATOR NAME (IF SAME AS OWNER, MARK BOX HERE [X])	
MAILING ADDRESS	
CITY	
STATE	
ZIP CODE	
TELEPHONE NUMBER	

C TANK/FACILITY LOCATION

FACILITY NAME (IF SAME AS OWNER, MARK BOX HERE [X])	BERRETH OIL PROPERTY SITE
MAILING ADDRESS (IF SAME AS OWNER, MARK BOX HERE [X])	
LOCATION OF TANKS	134 W. MISHAWAKA AVE.
CITY	MISHAWAKA IN 46544
STATE	IN
ZIP CODE	46544
COUNTY	ST. JOSEPH

TYPE OF FACILITY/OWNER

TYPE OF OWNER (Please Check One)	TYPE OF OPERATION (Please Check One)
<input checked="" type="radio"/> PRIVATE BUSINESS	<input type="radio"/> MOTOR VEHICLE FUEL DISPENSING STATION
<input type="radio"/> STATE GOVERNMENT	<input type="radio"/> COMMERCIAL
<input type="radio"/> LOCAL GOVERNMENT	<input type="radio"/> RESIDENTIAL
<input type="radio"/> FEDERAL GOVERNMENT	<input type="radio"/> INDUSTRIAL
<input type="radio"/> GSA FACILITY (ID# _____)	<input type="radio"/> AGRICULTURE
<input type="radio"/> OTHER	<input checked="" type="radio"/> OTHER

EFFECTIVE DATE OF OWNERSHIP: UNKNOWN

UTM COORDINATES: _____

D CONSULTANT/CONTRACTOR COMPLIANCE CERTIFICATION

DATE: I certify that the information concerning installation, upgrade, or closure provided in this notification is true and correct to the best of my knowledge.

NAME OF CONTRACTOR/CONSULTANT	SUNPRO JOHN BAMBER
NAME OF COMPANY	SUNPRO INC.
SIGNATURE OF CONTRACTOR/CONSULTANT	
CERTIFICATION NUMBER	UC2001441620
DATE	MAR 4 2004

CONTACT AT TANK LOCATION

NAME OF CONTACT PERSON AT TANK LOCATION	JOHN BAMBER
TITLE	PROJECT MGR.
TELEPHONE NUMBER	574-262-3556
NUMBER OF TANKS AT THIS LOCATION	2
NUMBER OF PAGES ATTACHED TO THIS NOTIFICATION	

OWNER CERTIFICATION

DATE: I certify that under penalty of law that I have personally examined and compared with the information submitted in this and attached documents, and that based on my inquiry of those individuals primarily responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

NAME AND TITLE OF OWNER OR AUTHORIZED REPRESENTATIVE	JEFF BERRETH
SIGNATURE OF OWNER (IN INK - NO PHOTOCOPIES WILL BE ACCEPTED)	
DATE	MARCH 4 2004

STATE USE ONLY

FACILITY NAME		FACILITY ID.		PAGE		STATE FORM 45223 (REV. 2/95)	
DESCRIPTION OF UNDERGROUND STORAGE TANK SYSTEM							
COMPLETE A COLUMN FOR EACH TANK.				ATTACH ADDITIONAL SHEETS WHEN NUMBER OF TANKS EXCEEDS SIX.			
E	SEQUENTIAL TANK NUMBER	A	B				
	OWNER-SPECIFIED TANK NUMBER						
F	DATE INSTALLED	UNK.	UNK.				
	CAPACITY (GALLONS)	3000	3000				
G	COMPLETE ONLY ONE OF 1, 2 OR 3. 1, 2 OR 3 MUST BE COMPLETED IF SECTIONS 4 OR 5 ARE SELECTED.	1. CURRENTLY IN USE	0	0	0	0	0
		DATE BROUGHT INTO USE					
		2. TEMPORARILY OUT OF USE	X	0	0	0	0
		DATE LAST USED	1980	1980			
		3. PERMANENTLY OUT OF USE					
H	TANK CONSTRUCTION	STEEL	0	0	0	0	0
		CONCRETE	0	0	0	0	0
		FIBERGLASS/PLASTIC	X	X	0	0	0
I	INTERNAL PROTECTION	INTERIOR LINING	0	0	0	0	0
		NONE	X	X	0	0	0
		UNKNOWN	0	0	0	0	0
J	EXTERNAL PROTECTION	CATHODIC	0	0	0	0	0
		PAINTED	0	0	0	0	0
		FIBERGLASS/PLASTIC	0	0	0	0	0
		NONE	X	X	0	0	0
K	TYPE	BARE STEEL	0	0	0	0	0
		GALVANIZED STEEL	0	0	0	0	0
		FIBERGLASS REINFORCED PLASTIC	0	0	0	0	0
		CATHODIC PROTECTION	0	0	0	0	0
		UNKNOWN	X	X	0	0	0
L	METHOD	PRESSURIZED	0	0	0	0	0
		EUROPEAN SUCTION	0	0	0	0	0
		AMERICAN SUCTION	0	0	0	0	0

STATE FORM 45223 (REV. 2/99)

FACILITY NAME _____ FACILITY ID. _____ PAGE _____ OF _____

DESCRIPTION OF UNDERGROUND STORAGE TANK SYSTEMS (CONTINUED)
 COMPLETE A COLUMN FOR EACH TANK. ATTACH ADDITIONAL SHEETS WHEN THE NUMBER OF TANKS EXCEEDS SIX.

Sequential Tank Number	A	B				
J (Only for use with tanks 2000 gallons or smaller) Manual Tank Gauging (Can only be used for 10 years) Tank Tightness Testing With Daily Inventory Controls (ATG must perform monthly leak test) Automatic Tank Gauging (Site Assessment required for use) Vapor Monitoring (Site Assessment required for use) Ground Water Monitoring (Site Assessment required for use) Interstitial Monitoring Within a Secondary Barrier Interstitial Monitoring Within Secondary Containment (Required for pressurized piping only) Automatic Line Leak Detectors (Required if tank leak detection does not cover piping) Line Tightness Testing Statistical Inventory Reconciliation (SIR) Another Method (Please specify below)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
K For Coated Steel Tanks with Cathodic Protection - Impressed Current Sacrificial Anodes For Coated Steel Piping with Cathodic Protection - Impressed Current Sacrificial Anodes Another Method (Please specify below)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
L (Required for most tanks) Catchment Basins (Valve attached to fill pipe) Automatic Shutoff Devices (MUST be audible to fuel delivery personnel) Overfill Alarms (Not recommended for use with weton piping) Ball Float Valves Another Method (Please specify below)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
M Installer is certified by the tank and piping manufacturer. Contractor is certified by the Office of the State Fire Marshal. Work inspected/certified by a registered professional engineer. Work inspected by the Office of the State Fire Marshal. All work has been completed. Another method of compliance was used (specify below).	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

CERTIFICATION OF FINANCIAL RESPONSIBILITY

N I have financial responsibility in accordance with Subtitle I Subpart H (Specify below).

<input type="radio"/> Self-Insurance	<input type="radio"/> Letter of Credit
<input type="radio"/> Insurance & Risk Retention Group Coverage	<input type="radio"/> Local Government - Bond Rating Test
<input type="radio"/> Trust Agreement	<input type="radio"/> Local Government - Financial Test
<input type="radio"/> Guarantee	<input type="radio"/> Local Government - Guarantee
<input type="radio"/> Surety Bond	<input type="radio"/> Local Government - Fund

30 - DAY REQUEST FOR TANK CLOSURE

O To request a tank closure, mark the Request for Closure oval in Type of Notification in Section A, complete sections B, C, D, E, and mark D, REQUESTING CLOSURE in section F. Complete the remaining sections (Q-N) and fill in the requested information below.

PROPOSED CONTRACTOR		LAST INCIDENT INFORMATION	
CONTRACTOR NAME SUNERG INC		LAST INCIDENT NUMBER, IF AVAILABLE	
MAILING ADDRESS 23843 CR 6 EAST UNIT B16-1A		DATE INCIDENT REPORTED	
ELKHART IN 46514		NOTE: Any tank closures must be permitted by persons authorized by the Indiana State Fire Marshal. Compliance with Departmental rules, including state fire marshal, and with US 1 Section must be completed 14 days prior to closure. Please report to the Indiana Department of State Police, Section at (317) 506-3067 if signs of soil or groundwater contamination are observed.	
PHONE 574-262-3556	CITY ELKHART	INDIAN STATE FIRE MARSHAL (317) 506-3067	
NAME JOHN BAMBER	CERTIFICATION NUMBER UC2001441620	Page 5 of 5	

FROM : DEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:26AM P11

SUNPRO

24 Hour Phone 800-488-0910
 Fax 574-262-9780
 www.sunproservices.com

MARCH 4, 2004

OFFICE OF STATE FIRE MARSHAL
 402 W. WASHINGTON STREET ROOM E-241
 INDIANAPOLIS IN 46204
 ATTN: TRACEY BOATWRIGHT

RE: 30-DAY NOTIFICATION OF UST CLOSURE

TANK OWNER:

BERRÉTH OIL COMPANY

PROPERTY OWNER / REPRESENTATIVE:

JEFF BERRETH

LOCATION OF UST:

BERRETH OIL PROPERTY SITE
 134 W. MISHAWAKA AVENUE
 MISHAWAKA IN 46544

COUNTY:

ST. JOSEPH

DATE OF REMOVAL:

WEEK OF APRIL 4, 2004.

TANK INFORMATION:

(2), 3,000 GALLON GASOLINE UST's

FIRE DEPARTMENT:

MISHAWAKA FIRE DEPARTMENT
 600 E. THIRD STREET
 MISHAWAKA IN 46544
 574-247-0928

UST REMOVAL CONTRACTOR:

SUNPRO INC.,
 23843 COUNTY ROAD 6 EAST
 UNIT B16-1A
 ELKHART IN 46514
 JOHN BAMBER
 OSFM CERTIFICATION UC2001441620


 JOHN BAMBER

SUNPRO INC.,

Michiana Regional Office: 23843 CR 6, Unit B-16-1A • Elkhart, Indiana 46514-9691
 Corporate Office: 7392 Whipple Ave., NW • North Canton, Ohio 44720-7140

UST CLOSURE REPORT DATA

1. OWNER / OPERATOR, OWNER ID NUMBER, ADDRESS, TELEPHONE NUMBER
BERRETH OIL COMPANY 1301 W. SIXTH ST. MISHAWAKA IN 46544
574-255-1255
2. CONTACT PERSON AND TELEPHONE NUMBER
MS. PEGGY BERRETH / JEFF BERRETH
3. PAST OWNER / OPERATOR OF FACILITY
BERRETH OIL COMPANY
4. UST CLOSURE CONTRACTOR
JOHN BAMBER
SUNPRO INC.,
23843 COUNTY ROAD 6 EAST, UNIT B16-1A
ELKHART IN 46514
5. NAME AND OFFICE OF STATE FIRE MARSHAL CERTIFICATION NUMBER
JOHN BAMBER
UC2001441620
COPY OF CERTIFICATION INCLUDED IN THIS REPORT
6. FACILITY NAME, ID NUMBER, ADDRESS, TELEPHONE NUMBER
NOT APPLICABLE
7. TYPE OF FACILITY, PAST AND PRESENT OWNERS
PROPERTY SITE HAS BEEN USED AS A USED AUTOMOBILE DEALERSHIP FOR THE
PAST SEVERAL YEARS.
8. COVERAGE
ASPHALT AND CONCRETE
9. HISTORY OF SPILLS / RELEASES
PER CURRENT OWNER - NONE
10. SITE SURROUNDINGS
PROPERTY IS BORDER BY CITY STREETS AND ALLEYS, RESIDENTIAL
PROPERTIES, APARTMENTS AND OFFICE BUILDINGS.
11. SITE SOIL TEXTURE
SANDY LOAM

12. SCALE OF SITE DIAGRAMS
AS IDENTIFIED ON EACH DRAWING LOWER RIGHT CORNER
13. BUILDINGS, STRUCTURES, SITE BOUNDARIES
AS IDENTIFIED ON SITE DRAWING INCLUDED IN THIS REPORT
14. LOCATION(S) OF ALL UNDERGROUND STORAGE TANKS AT SITE
AS IDENTIFIED ON SITE DIAGRAMS INCLUDED IN THIS REPORT
15. TANK REMOVAL EXCAVATIONS
AS IDENTIFIED ON SITE DIAGRAMS INCLUDED IN THIS REPORT
16. LOCATION(S) OF PREVIOUSLY CLOSED UST SYSTEM(S)
PER OWNER - NO OTHER UNDERGROUND STORAGE TANKS REMOVED FROM SITE
17. LOCATION(S) OF PUMP ISLAND(S)
AS IDENTIFIED ON SITE DIAGRAMS INCLUDED IN THIS REPORT
18. BURIED UTILITY LINES
GAS AND ELECTRIC LINES BURIED ALONG WEST EDGE OF PROPERTY SITE - SEE
SITE DIAGRAMS INCLUDED IN THIS REPORT
19. SOIL BORING LOCATIONS
NOT APPLICABLE
20. DRAINAGE
TO STORM DRAINS IN STREET
21. SAMPLING LOCATIONS
AS IDENTIFIED ON SITE DIAGRAMS INCLUDED IN THIS REPORT
22. GROUNDWATER MONITORING WELL LOCATIONS
NOT APPLICABLE
23. NUMBER AND VOLUME OF REMOVED UNDERGROUND STORAGE TANK(S)
TWO (2), 2,000 GALLON STEEL, GASOLINE UST SYSTEMS
TWO (2), 8,000 GALLON STEEL, GASOLINE UST SYSTEMS
24. PAST - PRESENT CONTENTS OF UNDERGROUND STORAGE TANKS
GASOLINE
25. CONSTRUCTION MATERIAL OF UNDERGROUND STORAGE TANKS
STEEL
26. AGE AND INSTALLATION DATE OF UNDERGROUND STORAGE TANKS
UNKNOWN
27. LEAK DETECTION
UNKNKNOWN

28. RECORDS OF TANK TIGHTNESS TESTING
NONE
29. RECORDS OF OTHER LEAK DETECTION
NONE
30. INFORMATION REGARDING PREVIOUSLY CLOSED UST SYSTEMS
NONE - UNKNOWN
31. DATA FROM ANALYSIS OF SOIL SAMPLING
INCLUDED IN THIS REPORT
32. DATA FROM ANALYSIS OF WATER SAMPLES
NOT APPLICABLE
33. SOIL SAMPLE IDENTIFICATION
SEE SITE DIAGRAMS INCLUDED IN THIS REPORT FOR IDENTIFICATION AND
LOCATIONS OF SOIL SAMPLES COLLECTED
34. ANALYTICAL METHODS USED
AS NOTED ON ANALYTICAL DATA COVER SHEET INCLUDED IN THIS REPORT
35. DETECTION LIMITS
AS NOTED ON ANALYTICAL DATA INCLUDED IN THIS REPORT
36. SIGNED CERTIFICATE OF ANALYSIS
INCLUDED WITH ANALYTICAL DATA IN THIS REPORT
37. CHAIN-OF-CUSTODY DOCUMENTATION
INCLUDED WITH ANALYTICAL DATA IN THIS REPORT
38. TIER II WASTE OIL ANALYSIS
NOT APPLICABLE
39. DECONTAMINATION PROCEDURES
SOIL SAMPLES WERE COLLECTED WITH DISPOSABLE EQUIPMENT
40. SAMPLING PROCEDURES AND TECHNIQUES
SOIL SAMPLES WERE COLLECTED DIRECTLY FROM UST AND PIPING RUN
EXCAVATION PITS WITH DISPOSABLE EQUIPMENT, PLACED INTO CLEAN, 40 CC
GLASS VIALS AND ICED INSIDE OF A SECURED, INSULATED COOLER. THE
SAMPLES WERE STORED IN AN OFFICE (SUNPRO) REFRIGERATOR, RE-ICED AND
HAND-DELIVERED TO EIS ANALYTICAL SERVICES OF SOUTH BEND, INDIANA, FOR
ANALYSIS OF TOTAL PETROLEUM HYDROCARBONS (TPH).
41. EXCAVATION SAMPLES
SEE SITE DIAGRAMS INCLUDED IN THIS REPORT FOR SOIL SAMPLING LOCATIONS

42. PIPING RUN SAMPLES
SEE SITE DIAGRAMS INCLUDED IN THIS REPORT FOR SOIL SAMPLING LOCATIONS
43. PUMP ISLAND SAMPLES
NO PUMP ISLAND SAMPLES WERE COLLECTED DUE TO PRESENCE OF OVERHEAD
CANOPY STRUCTURE.
44. DATE OF PERMANENT CLOSURE OF UST SYSTEMS
APRIL 24, 2004
45. SOIL BORING LOG LITHOLOGIC DESCRIPTION
NOT APPLICABLE
46. SOIL BORING LOG USING SAME VERTICAL SCALE
NOT APPLICABLE
47. DOCUMENTATION OF OVER-EXCAVATION ACTIVITIES
NOT APPLICABLE
48. APPROXIMATE AMOUNT OF SOIL EXCAVATED
123 CUBIC YARDS
49. DOCUMENTATION DISPOSAL OF SOILS / WATER
NOT APPLICABLE
50. DOCUMENTATION DISPOSAL OF PRODUCT-SLUDGE-RESIDUAL MATERIALS
CERTIFICATION OF DISPOSAL INCLUDED IN THIS REPORT
51. DOCUMENTATION DISPOSAL OF REMOVED UST SYSTEM
CERTIFICATION REGARDING DISPOSAL INCLUDED IN THIS REPORT



JOHN BAMBER

SUNPRO INC.,



PHOTO LOG

1. FILL PIPE OF 2,000 GALLON UST
2. VIEW SOUTHWARD DURING EXCAVATION TO TOPS OF (2), 2,000 GALLON UST'S
3. TOPS OF (2) 2,000 GALLON UST'S
4. 2,000 GALLON UST'S CUT OPEN
5. VIEW SOUTHWARD DURING REMOVAL OF 2,000 GALLON UST
6. VIEW SOUTHWEST DURING REMOVAL OF 2,000 GALLON UST
7. VIEW SOUTHWARD DURING REMOVAL OF 2,000 GALLON UST
8. VIEW OF 2,000 GALLON UST EXCAVATION PIT
9. VIEW EASTWARD OF (2) 8,000 GALLON UST'S
10. HOLE CUT IN TOP OF 8,000 GALLON UST
11. VIEW WESTWARD DURING REMOVAL OF 8,000 GALLON UST
12. SAME AS PREVIOUS PHOTO
13. SAME AS PREVIOUS PHOTO
14. SAME AS PREVIOUS PHOTO
15. SAME AS PREVIOUS PHOTO AND VIEW OF EXCAVATION PIT
16. VIEW SOUTHWARD OF FOUR (4) UST VENT PIPES
17. UST VENT PIPES REMOVED
18. VIEW NORTHWARD DURING SITE RESTORATION
19. VIEW WESTWARD DURING SITE RESTORATION
20. SAME AS PREVIOUS PHOTO

FROM : DEP1-SB

FRX NO. : 5742341615

Nov. 08 2005 09:29PM P2




NOV-08-2005 09:30

5742341615

98%


P.02



FROM : QEP1-SB

FAX NO. : 5742341615

NOV 08 2005 09:32AM P4



NOV-08-2005 09:33

5742341615

98%

P.04

FROM : DEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:34AM PS



NOV-08-2005 09:35

5742341615



98%

P.05

FROM : DEPI-SB

FRX NO. : 5742341615

Nov. 08 2005 09:35AM P6




NOV-08-2005 09:35

5742341615

98%

P.06



Location of St. Joseph County in Indiana.

FIGURE 1.




FIGURE 2.





FIGURE 3.

12'30"

SCALE 1:24,000





SITE




FIGURE 4.
SCALE: 1" = 20'



SITE




FIGURE 5.
SCALE: 1" = 20'



SITE




FIGURE 6.
SCALE: 1" = 20'



SITE




FIGURE 7.
SCALE: 1" = 20'



SITE




FIGURE 8.
SCALE: 1" = 10'



SITE




FIGURE 9.
SCALE: 1" = 10'



SITE




FIGURE 10.
SCALE: 1" = 10'



SITE




FIGURE 11.
SCALE: 1" = 10'

CLEARANCE SOIL SAMPLING			
SAMPLE ID	LOCATION	ANALYSIS	RESULTS
AA	BELOW FILL 2000 GAL. UST 9 FT. BGL	TPH 8260	< 20 PPM
AB	BELOW VENT 2000 GAL. UST 9 FT. BGL	TPH 8260	< 20 PPM
AC	BELOW FILL 2000 GAL. UST 9 FT. BGL	TPH 8260	< 20 PPM
AD	BELOW VENT 2000 GAL. UST 9 FT. BGL	TPH 8260	< 20 PPM
AE	WEST WALL 2000 GAL. UST 6 FT. BGL	TPH 8260	< 20 PPM
AF	NORTH WALL 2000 GAL. UST 6 FT. BGL	TPH 8260	< 20 PPM
AG	EAST WALL 2000 GAL. UST 6 FT. BGL	TPH 8260	< 20 PPM
AH	SOUTH WALL 2000 GAL. UST 6 FT. BGL	TPH 8260	< 20 PPM
AI	BACKFILL SOILS 2000 GAL. UST'S 56 CYS	TPH 8260	< 20 PPM
AJ	BELOW FILL 8000 GAL. UST 12 FT. BGL	TPH 8260	< 20 PPM
AK	BELOW VENT 8000 GAL. UST 12 FT. BGL	TPH 8260	< 20 PPM
AL	BELOW FILL 8000 GAL. UST 12 FT. BGL	TPH 8260	< 20 PPM
AM	BELOW VENT 8000 GAL. UST 12 FT. BGL	TPH 8260	< 20 PPM
AN	NORTH WALL 8000 GAL. UST 7 FT. BGL	TPH 8260	< 20 PPM
AO	WEST WALL 8000 GAL. UST 7 FT. BGL	TPH 8260	< 20 PPM
AP	EAST WALL 8000 GAL. UST 7 FT. BGL	TPH 8260	< 20 PPM
AQ	SOUTH WALL 8000 GAL. UST 7 FT. BGL	TPH 8260	< 20 PPM
AR	BACKFILL SOILS 8000 GAL. UST'S 67 CYS	TPH 8260	< 20 PPM

(BGL) = BELOW GRADE LEVEL

FROM : QEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:45AM P19



REPORT OF ANALYSIS

John Bamber
18105 Chipstead
South Bend, IN 46637
Tel No: 574-849-0264
Fax No:
PO No: 04-04-BOC
Project Name: Mishawaka

Report Date: 5/3/04
EIS Order No: 040400217
EIS Sample No: 095589
EIS Project No: 3140-1000-04

Client Sample ID: BOC AA
Date Collected: 4/24/04
Date Received: 4/26/04
Collected By: J. Bamber

This report presents results of analysis for your sample(s) received under our Order No above. This Number is to be used in all inquiries concerning this report. The EIS Sample No above, as well as your Sample ID, refer to the first sample in a multi-sample submission

DEFINITIONS:

RDL = Reporting Detection Limit for your sample and may include adjustments for matrix interferences.
nd = Not Detected at the RDL value. If present, result is less than this value.
< = Not Detected at the numerical value shown. If present, result is less than this value.
() = Result is estimated due to matrix interferences or calibration curve exceedence.

CHAIN-OF-CUSTODY is enclosed if received with your sample submission.

DRINKING WATER CERTIFICATIONS: Chemistry = C-71-02 Bacteriology = M-76-5

QUALITY ASSURANCE OFFICER


LABORATORY DIRECTOR

The data in this report has been reviewed and complies with EIS Quality Control unless specifically addressed above.

EIS Analytical Services Inc 1701 N. Ironwood Drive, Suite B * South Bend, IN 46635 * Tel: 574-277-0707 * Fax: 574-273-5699

FROM : OEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:45AM P20

SAMPLE PREPARATION INFORMATION

Client Name: John Bamber
 Client Project:: Mishawaka

Report Date: 5/3/04
 EIS Order No: 040400217

EIS Lab Number	Client Description	Sample Date	Procedure	Result	Date Completed	Analyst	Method
095569	BOC AA	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095570	BOC AB	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095571	BOC AC	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095572	BOC AD	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095573	BOC AE	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095574	BOC AF	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095575	BOC AG	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095576	BOC AH	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095577	BOC AI	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095578	BOC AJ	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095579	BOC AK	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095580	BOC AL	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095581	BOC AM	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095582	BOC AN	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095583	BOC AO	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095584	BOC AP	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095585	BOC AQ	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B
095586	BOC AR	4/24/04	Extract BETX/TPH	Complete	4/28/04	E16	8260 B

EIS Analytical Services, Inc.

1701 North Ironwood Drive, Suite B • South Bend, IN 46635 • 574-277-0707 • Fax: 574-273-5699

FROM : GEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:46AM P21

SAMPLE RESULTS

Client Name: John Bamber
 Client Project: Mishawaka

Page 2 of 3

Report Date: 5/3/04
 EIS Order No: 040400217

EIS Lab Number	Client Description	Sample Date	Parameter	Result	Units	RDL	Test Date	Analyst ID	Method
095569	BOC AA	4/24/04	Moisture(%)	7.6	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095570	BOC AB	4/24/04	Moisture(%)	7.8	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095571	BOC AC	4/24/04	Moisture(%)	8.5	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095572	BOC AD	4/24/04	Moisture(%)	3.5	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095573	BOC AE	4/24/04	Moisture(%)	8.2	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095574	BOC AF	4/24/04	Moisture(%)	8.6	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095575	BOC AG	4/24/04	Moisture(%)	9.4	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095576	BOC AH	4/24/04	Moisture(%)	9	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095577	BOC AI	4/24/04	Moisture(%)	7.9	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095578	BOC AJ	4/24/04	Moisture(%)	8.3	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095579	BOC AK	4/24/04	Moisture(%)	8.3	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095580	BOC AL	4/24/04	Moisture(%)	10	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095581	BOC AM	4/24/04	Moisture(%)	7.9	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095582	BOC AN	4/24/04	Moisture(%)	8.0	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095583	BOC AO	4/24/04	Moisture(%)	8.4	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B

EIS Analytical Services, Inc. 1701 North Ironwood Drive, Suite B * South Bend, IN 46635 * 574-277-0707 * Fax: 574-273-5699

FROM : QEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:46AM P22

SAMPLE RESULTS

Client Name: John Bamber
 Client Project: Mishawaka

Page 3 of 3

Report Date: 5/3/04
 EIS Order No: 040400217

EIS Lab Number	Client Description	Sample Date	Parameter	Result	Units	RDL	Test Date	Analyst ID	Method
095584	BOC AP	4/24/04	Moisture(%)	7.8	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095585	BOC AQ	4/24/04	Moisture(%)	8.3	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B
095586	BOC AR	4/24/04	Moisture(%)	9.2	%	0.1	4/28/04	E21	160.3
		4/24/04	TPH (GRO)	<20	mg/kg(wet)	20	4/29/04	E04	8260 B

EIS Analytical Services, Inc. 1701 North Ironwood Drive, Suite B * South Bend, IN 46635 * 574-277-0707 * Fax: 574-273-5699

QUALITY ASSURANCE / QUALITY CONTROL DATA
Method Specific Surrogate Compound Recoveries

EIS Order ID: 040400217

Normal Test	Surrogate	QUALITY CONTROL LIMITS			
		Methods		QC Limits	
		Water	Soil	Water	Soil
Herbicides	2,4-Dichlorophenylacetic acid (DCAA)	615 / 8151A / 8270C	8270C	15 - 135	
Pesticides / PCB	2,4,5,6-Tetrachloro-m-xylene (TCMX)	608 / 8081A / 8082 / 508	8082	22 - 145	
Pesticides / PCB	Decachlorobiphenyl (DCB)	608 / 8081A / 508	8082	22 - 145	40 - 150
SOC (svoc)	Perylene, d12	525.2		30 - 140	40 - 150
SVOC (acid)	2-Fluorophenol	625 / 8270C	8270C	21 - 100	
SVOC (acid)	Phenol, d5	625 / 8270C	8270C	10 - 94	25 - 121
SVOC (base/neutral)	Nitrobenzene, d5	625 / 8270C	8270C	35 - 114	24 - 113
SVOC (base/neutral)	2-Fluorobiphenyl	625 / 8270C	8270C	43 - 116	23 - 120
SVOC (acid)	2,4,6-Tribromophenol	625 / 8270C	8270C	10 - 123	30 - 115
SVOC (base/neutral)	Terphenyl, d14	625 / 8270C	8270C	33 - 141	19 - 122
TPH	Styrene	8015M	8015M	30 - 90	18 - 137
VOC / BETX / TPH	1,2-Dichloroethane, d4	624 / 8260B / 524.2	8260B	70 - 130	34 - 90
VOC / BETX / TPH	Toluene, d8	624 / 8260B / 524.2	8260B	70 - 130	70 - 130
VOC / BETX / TPH	Bromofluorobenzene (BFB)	624 / 8260B / 524.2	8260B	70 - 130	70 - 130

EIS Lab No	Client Sample ID	Method	Matrix	Surrogate	%Recovery
095569	BOC AA	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	91
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	75
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	97
095570	BOC AB	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	88
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	84
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	94
095571	BOC AC	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	92
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	84
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	97
095572	BOC AD	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	87
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	93
095573	BOC AE	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	90
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	85
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	99
095574	BOC AF	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	88
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	95
095575	BOC AG	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	90
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	84
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	100
095576	BOC AH	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	78
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	99

Legend: -1 = Surrogates diluted out -2 = Surrogates not used -999 = Interference in response area

QUALITY ASSURANCE / QUALITY CONTROL DATA
Method Specific Surrogate Compound Recoveries

EIS Order ID: 040400217

Normal Test	Surrogate	QUALITY CONTROL LIMITS			
		Methods		QC Limits	
		Water	Soil	Water	Soil
Herbicides	2,4-Dichlorophenylacetic acid (DCAA)	615 / 8151A / 8270C	8270C	15 - 135	
Pesticides / PCB	2,4,5,6-Tetrachloro-m-xylene (TCMX)	608 / 8081A / 8082 / 508	8082	22 - 145	
Pesticides / PCB	Decachlorobiphenyl (DCB)	608 / 8081A / 508	8082		40 - 150
SOC (svoc)	Perylene, d12	525.2		22 - 145	40 - 150
SVOC (acid)	2-Fluorophenol	625 / 8270C		30 - 140	
SVOC (acid)	Phenol, d5	625 / 8270C	8270C	21 - 100	25 - 121
SVOC (base/neutral)	Nitrobenzene, d5	625 / 8270C	8270C	10 - 94	24 - 113
SVOC (base/neutral)	2-Fluorobiphenyl	625 / 8270C	8270C	35 - 114	23 - 120
SVOC (acid)	2,4,6-Tribromophenol	625 / 8270C	8270C	43 - 116	30 - 115
SVOC (base/neutral)	Terphenyl, d14	625 / 8270C	8270C	10 - 123	19 - 122
TPH	Styrene	625 / 8270C	8270C	33 - 141	18 - 137
VOC / BETX / TPH	1,2-Dichloroethane, d4	8015M	8015M	30 - 90	34 - 90
VOC / BETX / TPH	Toluene, d8	624 / 8260B / 524.2	8260B	70 - 130	70 - 130
VOC / BETX / TPH	Bromofluorobenzene (BFB)	624 / 8260B / 524.2	8260B	70 - 130	70 - 130

EIS Lab No	Client Sample ID	Method	Matrix	Surrogate	%Recovery
095577	BOC AI	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	91
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	87
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	96
095578	BOC AJ	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	92
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	83
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	98
095579	BOC AK	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	88
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	99
095580	BOC AL	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	87
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	81
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	97
095581	BOC AM	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	87
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	83
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	99
095582	BOC AN	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	69
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	96
095583	BOC AO	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	83
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	96
095584	BOC AP	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	90
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	99

Legend: -1 = Surrogates diluted out -2 = Surrogates not used -999 = Interference in response area

FROM : QEP1-SB

FAX NO. : 5742341615

Nov. 08 2005 09:47AM P25

QUALITY ASSURANCE / QUALITY CONTROL DATA
Method Specific Surrogate Compound Recoveries

EIS Order ID: 040400217

QUALITY CONTROL LIMITS

Normal Test	Surrogate	Methods		QC Limits	
		Water	Soil	Water	Soil
Herbicides	2,4-Dichlorophenylacetic acid(DCAA)	615 / 8151A / 8270C	8270C	15 - 135	
Pesticides / PCB	2,4,5,6-Tetrachloro-m-xylene(TCMX)	608 / 8081A / 8082 / 508	8082	22 - 145	
Pesticides / PCB	Decachlorobiphenyl(DCB)	608 / 8081A / 508	8082	22 - 145	40 - 150
SOC (svoc)	Perylene, d12	525.2		30 - 140	40 - 150
SVOC (acid)	2-Fluorophenol	625 / 8270C		21 - 100	
SVOC (acid)	Phenol, d5	625 / 8270C	8270C	10 - 94	25 - 121
SVOC (base/neutral)	Nitrobenzene, d5	625 / 8270C	8270C	35 - 114	23 - 120
SVOC (base/neutral)	2-Fluorobiphenyl	625 / 8270C	8270C	43 - 116	30 - 115
SVOC (acid)	2,4,6-Tribromophenol	625 / 8270C	8270C	10 - 123	19 - 122
SVOC (base/neutral)	Terphenyl, d14	625 / 8270C	8270C	33 - 141	18 - 137
TPH	Styrene	8015M	8015M	30 - 90	34 - 90
VOC / BETX / TPH	1,2-Dichloroethane, d4	624 / 8260B / 524.2	8260B	70 - 130	70 - 130
VOC / BETX / TPH	Toluene, d8	624 / 8260B / 524.2	8260B	70 - 130	70 - 130
VOC / BETX / TPH	Bromofluorobenzene(BFB)	624 / 8260B / 524.2	8260B	70 - 130	70 - 130

EIS Lab No	Client Sample ID	Method	Matrix	Surrogate	%Recovery
095585	BOC AQ	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	88
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	85
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	100
095586	BOC AR	8260 B	Soil/Sludge/Solid	1,2-Dichloroethane-d4 (SS)	89
		8260 B	Soil/Sludge/Solid	4-Bromofluorobenzene (SS)	82
		8260 B	Soil/Sludge/Solid	Toluene-d8 (SS)	100

Legend: -1 = Surrogates diluted out -2 = Surrogates not used -999 = Interference in response area

SUNPRO CHAIN OF CUSTODY

FROM : DEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:48PM P26

NOV-08-2005 09:48

5742341615

Project No. 04-04-BOC			Sampler: (Signature) <i>John Bamser</i>		Printed Name JOHN BAMSER		ANALYSIS										PRIORITY	REMARKS 0404.217						
Project Location MISHAWAKA													PCB by Arochlor	BTEX	Fluid Quality	DGA			FURAN	Solvent Exchange	IPH	GRO		
Sample No.	Date	Time	Location or Equipment No.	Sample Type																				
BOC AA	4/24	14:00		SOIL																				
BOC AB																		95567						
BOC AC																		95570						
BOC AD																		95571						
BOC AE																		95572						
BOC AF																		95573						
BOC AG																		95574						
BOC AH																		95575						
BOC AI																		95576						
BOC AJ																		95577						
BOC AK																		95578						
BOC AL																		95579						
BOC AM																		95580						
BOC AN																		95581						
BOC AO																		95582						
BOC AP																		95583						
BOC AQ																		95584						
BOC AR	V	V															95585							
																	95586							

_____ as an authorized agent of _____ (the Company) certifies that the equipment/area sampled by SUNPRO, INC. has been left in the same condition as prior to sampling. The Company relinquishes the above listed sample(s) to the care and custody of SUNPRO, INC., to be transported and delivered to the below listed analytical laboratory. The Company agrees to hold SUNPRO, INC. harmless for any liability resulting from subsequent leaks, mechanical and/or electrical failure of any equipment/area. The Company also accepts all liability for any spills which are the result of the Company's actions or equipment failure such as but not limited to a faulty sampling valve.

Authorized Agent: (Signature) <i>John Bamser</i>	Date 4/24/04	Time 0700	Received by: (Signature) <i>David Kye</i>	Relinquished by: (Signature)	Date	Time	Received by: (Signature)
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Relinquished by: (Signature)	Date	Time	Received by: (Signature)
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Relinquished by: (Signature)	Date	Time	Received by: (Signature)

SUNPRO 7392 Whipple Ave., N.W. North Canton, OH 44720	24 Hr. Hotline (330) 966-0910	Laboratory _____ Address _____ City, State, Zip _____	Phone _____
---	----------------------------------	---	-------------

98%

P.26

SUNPRO

24 Hour Phone 800-488-0910

Fax 574-262-9780

www.sunproservices.com

CERTIFICATION**DISPOSAL OF REMOVED UNDERGROUND STORAGE TANK**

This is to certify that the underground storage tank as specifically identified herein, was removed and disposed of in accordance with the American Petroleum Institute's Recommended Practice for abandonment or Removal and Disposal of USED UNDERGROUND STORAGE TANKS, API BULLETIN 1604

TANK REMOVAL SITE LOCATION

BERRETH OIL COMPANY PROPERTY SITE
134 W. MISHAWAKA AVENUE
MISHAWAKA IN 46544

TANK DISPOSAL SITE LOCATION

STURGIS IRON & METAL COMPANY
LUSHER AVENUE
ELKHART IN

DESCRIPTION OF REMOVED UNDERGROUND STORAGE TANKS

(2) 2,000 GALLON STEEL UST's
(2) 8,000 GALLON STEEL UST's



JOHN BAMBER

SUNPRO INC.,

APRIL 24, 2004

Michiana Regional Office: 23843 CR 6, Unit B-16-1A • Elkhart, Indiana 46514-9691
Corporate Office: 7392 Whipple Ave., NW • North Canton, Ohio 44720-7140

FROM : QEPI-SB

FAX NO. : 5742341615

Nov. 08 2005 09:49AM P28

SUNPRO

24 Hour Phone 800-488-0910

Fax 574-262-9780

www.sunproservices.com

CERTIFICATION**DISPOSAL OF PRODUCT-SLUDGE-RESIDUAL MATERIAL(S)****WHEREAS:**

The undersigned does hereby certify that during the permanent closure of four (4) underground storage tank (UST) systems as located at:

**BERRETH OIL COMPANY PROPERTY SITE
134 W. MISHAWAKA AVENUE
MISHAWAKA IN 46544**

D-B ENVIRONMENTAL SERVICES REMOVED

478 GALLONS

of product, sludge, residual material(s). These materials will be disposed of at:

**FUTURE ENVIRONMENTAL INC.,
19701 S. 97TH AVENUE
MOKENA IL 60448
USEPA ID NO. ILD984831396**

for treatment (reclamation) as an industrial fuel source and for treatment - disposal via a wastewater treatment plant facility.



JOHN BAMBER

SUNPRO INC.,

APRIL 24 2004

Michiana Regional Office: 23843 CR 6, Unit B-16-1A • Elkhart, Indiana 46514-9691
Corporate Office: 7392 Whipple Ave., NW • North Canton, Ohio 44720-7140

NOV-08-2005 09:50

5742341615

98%

P.28