



# AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeff Teagarden  
Dore & Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker - Phase IV  
Engineering Building (Building # 92)

Project No. 11.2466

Date Inspected: December 21, 2010

Analysis/Method: Asbestos - Bulk Material / Polarized Light Microscopy (EPA 600/M4-82-020)

\*\*\*\*\*


SAMPLE ID	MATRIX	LOCATION and DESCRIPTION	ASBESTOS	NON-ASBESTOS
92-01C	Misc	Second Floor - East Side of Building Window Glazing	ND	99-100% Binder

ND = None Detected (Asbestos not detected above the detection limit of PLM Methodology.)

Analyzed by: SAC

Ref Number: 293994

Inspector:

  
 Jeffrey Rugg  
 IDEM License # 104722076  
 Expiration Date: 09/24/2011

BUR = Built-up Roofing  
 TSI = Thermal System Insulation  
 Surf = Surfacing Material  
 Misc = Miscellaneous Material  
 Other = Binder Constituents





# AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT ©  15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeffrey C. Teagarden  
Dore and Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker Phase IV  
Foundry Building - Building # 85  
Engineering Building - Building # 92

Project No. 10.2466

Analysis: Point Count Asbestos - Bulk Material

Method: Polarized Light Method: EPA 600/M4-82-020  
Quantitation using 400 Point Count Procedure

\*\*\*\*\*


SAMPLE ID	MATRIX	LOCATION and DESCRIPTION	Points on Asbestos	Points on Non-Asbestos	% Asbestos
85-07A	Misc	Foundry (Building # 85) Second Floor - Large Open Area Window Glazing	7	393	1.75
92-01B	Misc	Engineering Building (Building # 92) First Floor - West Side of Building Window Glazing	3	397	0.75

ND=None Detected (Asbestos not detected above the detection limit of PLM Methodology.)

Analyzed by: SAC

Ref Number(s): 293995 & 293997

Inspector: \_\_\_\_\_

  
Jeffrey Rugg  
IDEM License # 194722076  
Expiration Date: 09/24/2011

BUR = Built-up Roofing  
TSI = Thermal System Insulation  
Surf = Surfacing Material  
Misc = Miscellaneous Material  
Other = Binder Constituents





# AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

## SAMPLE LOG FORM and ANALYTICAL REPORT

Client: Mr. Jeff Teagarden  
Dore & Associates Contracting, Inc.  
900 Harry S. Truman Parkway  
Bay City, Michigan 48706

Project: Studebaker - Phase IV  
Foundry Building (Building # 85)

Project No. 11.2466

Date Inspected: December 21, 2010

Analysis/Method: Asbestos - Bulk Material / Polarized Light Microscopy (EPA 600/M4-82-020)

SAMPLE ID	MATRIX	LOCATION and DESCRIPTION	ASBESTOS	NON-ASBESTOS
85-07B	Misc	Second Floor - West Middle Office Window Glazing	NA	--
85-07C	Misc	Second Floor - Southwest Locker Room Window Glazing	NA	--


**Notes:**

ND = None Detected (Asbestos not detected above the detection limit of PLM Methodology.)  
NA = Not Analyzed

Analyzed by: SAC

Ref Number: 293996

Inspector:

  
Jeffrey Rugg  
IDEM License # 194722076  
Expiration Date: 09/24/2011

BUR = Built-up Roofing  
TSI = Thermal System Insulation  
Surf = Surfacing Material  
Misc = Miscellaneous Material  
Other = Binder Constituents

