February 28, 2011

Mr. Jeffrey C. Teagarden Dore and Associates Contracting, Inc. 900 Harry S. Truman Parkway Bay City, Michigan 48706

RE:

Asbestos Abatement Studebaker – Area "A"

Foundry Bldg. Mech./Boiler Room

Project # 11.2557

Dear Mr. Teagarden,

Thank you for the opportunity to provide Dore and Associates Contracting, Inc. with this service. Please find attached the analytical report for the air samples taken from the above location for the negative exposure assessment during the asbestos abatement on 2-23-11.

The air samples analyses verified that the airborne fiber concentration was below the Permissible Exposure Level (PEL) of 0.10 fibers per cubic centimeter of air, as defined by the United States Environmental Protection Agency, and the Occupational Safety and Health Administration.

The analysis was performed in accordance with all applicable state and federal rules and regulations governing asbestos abatement projects in public and commercial buildings. Quality control criteria specific to the analytical method have been met. All QA/QC documentation will remain on file for future reference.

Please call if you have any questions or if we can be of any additional service.

Respectfully,

John Blosky Asbestos Inspector

License # 198701061

Attachments: Fiber Concentration Report

## **Fiber Concentration Report**

DATE: February 23, 2011

ANALYTICAL METHOD: PCM - NIOSH Method 7400

CONTRACTOR:

Dore & Associates Contracting

Inc.

PROJECT:

Studebaker Area "A"

400-450X Magnification

Foundry Building

**CLIENT PROJECT #:** 

AMERECO PROJECT #: 11.2557

REPORTED TO:

Mr. Jeff Teagarden

REPORTED TO

Dore & Associates Contracting 900 Harry S. Truman Parkway

P.O. Box 146 Bay City, MI 48707

The following is the analyses of 11 air samples taken during the asbestos removal project at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

IA - Inside Area OA - Outside Area NEG - Negative Air	Sample Type:	PER - Personal IA - Inside Area	BKG - Background OA - Outside Area	CLR - Clearance NEG - Negative Air	IAQ - Indoor Air Quality
---	--------------	------------------------------------	---------------------------------------	---------------------------------------	--------------------------

Activity:	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out ** - Excursion	TWA - 8hr. Time Weighted Avg.
-----------	-------------------------------------	---------------------------------	-----------------------------	----------------------------------

Sample ID	Date Collected	Sample Type/ Activity	Location	Fibers/ CC
01	2-23-11		Lab Blank	
02	2-23-11		Field Blank	
03	2-23-11	PER/GR	Nicholas Zuniga Asbestos License # 19A002195	0.08
04	2-23-11	PER/GR	German Hernandez Asbestos License # 19A002654	0.03
05	2-23-11	IA/GR	Mechanical/Boiler Room Foundry Bldg.	0.03
06	2-23-11	OA/GR	Mechanical/Boiler Room Foundry Bldg.	<0.01
07	2-23-11	PER/GR	Nicholas Zuniga Asbestos License # 19A002195	0.02
08	2-23-11	IA	Mechanical/Boiler Room Foundry Bldg.	0.03
09	2-23-11	ОА	Mechanical/Boiler Room Foundry Bldg.	<0.01

Sample ID	Date Collected	Sample Type/ Activity	Location	Fibers/ CC
10	2-23-11	PER/GR	German Hernandez Asbestos License # 19A002654	0.03
11	2-23-11	**	Nicholas Zuniga Asbestos License # 19A002195	0.01
	2-23-11	TWA	Nicholas Zuniga Asbestos License # 19A002195	0.02
	2-23-11	TWA	German Hernandez Asbestos License # 19A002654	0.02

Note: 1. Samples analyzed by Amereco. 2. OL = Overloaded and can not be analyzed 3. ND = None Detected

Analyzed by: