



AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 15

Fiber Concentration Report

DATE: February 23, 2011 **CONTRACTOR:** Dore & Associates Contracting Inc.
PROJECT: Studebaker Area "A" Foundry Building **CLIENT PROJECT #:** 1719
AMERECO PROJECT #: 11.2556 **REPORTED TO:** Mr. Jeff Teagarden
ANALYTICAL METHOD: PCM - NIOSH Method 7400 400-450X Magnification Dore & Associates Contracting
900 Harry S. Truman Parkway
P.O. Box 146
Bay City, MI 48707

The following is the analyses of 8 air samples taken during the asbestos removal project at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

Sample Type:	PER - Personal IA - Inside Area	BKG - Background OA - Outside Area	CLR - Clearance NEG - Negative Air	IAQ - Indoor Air Quality
---------------------	------------------------------------	---------------------------------------	---------------------------------------	--------------------------

Activity:	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out ** - Excursion	TWA - 8hr. Time Weighted Avg.
------------------	-------------------------------------	---------------------------------	--------------------------------	----------------------------------

Sample ID	Date Collected	Sample Type/ Activity	Location	Fibers/ CC
1	2-21-11	PER	Rene Gonzalez Asbestos License # Not Provided by Contractor	0.012
2	2-21-11	PER	Ed Berbe Asbestos License # Not Provided by Contractor	0.016
3	2-21-11	PER	Rene Gonzalez Asbestos License # Not Provided by Contractor	<0.01
4	2-21-11	PER	Ed Berbe Asbestos License # Not Provided by Contractor	<0.01
----	2-21-11	TWA	Rene Gonzalez Asbestos License # Not Provided by Contractor	0.012
----	2-21-11	TWA	Ed Berbe Asbestos License # Not Provided by Contractor	0.012
1	2-22-11	PER	Cesar Zuniga Asbestos License # Not Provided by Contractor	<0.01
2	2-22-11	PER	Nicholas Zuniga Asbestos License # Not Provided by Contractor	<0.01
3	2-22-11	PER	Cesar Zuniga Asbestos License # Not Provided by Contractor	0.01



Sample ID	Date Collected	Sample Type/ Activity	Location	Fibers/ CC
4	2-22-11	PER	Nicholas Zuniga Asbestos License # Not Provided by Contractor	0.015
----	2-22-11	TWA	Ceasar Zuniga Asbestos License # Not Provided by Contractor	0.01
----	2-22-11	TWA	Nicholas Zuniga Asbestos License # Not Provided by Contractor	0.01

- Note: 1. Samples taken by Contractor.
2. Samples analyzed by Amereco.
3. OL = Overloaded and can not be analyzed
4. ND = None Detected

Analyzed by: _____

