

April 7, 2011

Mr. Jeff Teagarden Dore & Associates Contracting 900 Harry S. Truman Parkway P.O. Box 146 Bay City, MI 48707

Re:

Post ACM Removal Clearance Report Studebaker - Foundry (Building #85)

Roof-Top Elevator Room and Northeast Tunnel

South Bend, IN Project #: 11.2610

Dear Mr. Teagarden:

Attached please find the clearance report for the air samples collected, on April 4, 2011, following the removal of asbestos-containing materials surrounding tank in the Roof-Top Elevator Room and the Northeast Tunnel at the above captioned location.

The air sample analyses verified that the air quality remained within acceptable limits as defined by the United States Environmental Protection Agency, the Indiana Department of Environmental Management, and the Occupational Safety and Health Administration.

Please call if you have any questions.

Respectfully submitted,

James Kurtz

Asbestos Inspector

License # 19A003767

Attachment



## Fiber Concentration Report

DATE:

April 4, 2011

CONTRACTOR:

Dore & Associates Contracting

PROJECT:

Studebaker Area "A"

400-450X Magnification

Foundry Building

CLIENT PROJECT #:

AMERECO PROJECT #: 11.2610

ANALYTICAL METHOD: PCM - NIOSH Method 7400

REPORTED TO:

Mr. Jeff Teagarden

Dore & Associates Contracting 900 Harry S. Truman Parkway

P.O. Box 146

Bay City, MI 48707

The following is the analyses of 4 air samples taken following the asbestos removal project at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

Sample Type:	PER - Personal IA - Inside Area	BKG - Background OA - Outside Area	CLR - Clearance NEG - Negative Air	IAQ - Indoor Air Quality
--------------	------------------------------------	---------------------------------------	---------------------------------------	--------------------------

Activity:	GR - Gross Removal		BO - Bag Out	TWA - 8hr. Time
II .	CU - Clean Up	PR - Site Prep	** - Excursion	Weighted Avg.

Sample ID	Date Collected	Sample Type/ Activity	Location	Fibers/ CC
CLR-01	4/4/11	CLR	IA- Roof-Top Elevator Room	<0.01
CLR-02	4/4/11	CLR	OA- Roof-Top Elevator Room	<0.01
CLR-03	4/4/11	CLR	IA- Northeast Tunnel North Entrance	<0.01
CLR-04	4/4/11	CLR	IA- Northeast Tunnel South Entrance	<0.01

Note: 1. Samples analyzed by Amereco.

2. OL = Overloaded and can not be analyzed

3. ND = None Detected

Analyzed by