



AMERECO, INC.

CONSULTING • ENGINEERING • PROJECT MANAGEMENT © 2015

February 23, 2012

Mr. Jeffrey C. Teagarden
Dore and Associates Contracting, Inc.
900 Harry S. Truman Parkway
Bay City, Michigan 48706

**Re: UST Closure – 14
Summary of Activities
Studebaker Phase IV
Project # - 11.2529.16**

Dear Mr. Teagarden,

Attached, please find the Project Narrative kept by Ameresco Inc. and photographic documentation in association with the removal of one (1) underground storage tanks (USTs). Ameresco provided oversight during the removal of the UST on January 25, 2012.

Ameresco oversaw the removal of the USTs 14 from the ground on January 25, 2012. The UST was empty and free of liquid when Ameresco arrived onsite. Dore and Associates removed these USTs from the earth and staged/stabilized the tank for cleaning. This is to be completed by Dore & Associates at a later date, prior to disposal. The USTs were labeled to complete the removal process for the day.

The UST was later disposed of by Dore & Associates at Omni Source of South Bend, Indiana. A copy of the Certificate of Destruction is attached to this document as well.

Please call if you have any questions or if we can be of further assistance.

Respectfully submitted,


Zachary Heine
Environmental Manager
State of Indiana Certified for UST Decommissioning
Certificate #UC20098078
Expiration: 03/20/2013

Attachments: Project Narrative
Photographic Documentation
Certificate of Destruction






Project Narrative

February 23, 2012

- 8:00 AM Amereco arrives onsite. The UST located adjacent to the project trailer, near the West side of the project site. UST 14 has been previously uncovered but will require limited soil excavating to remove. UST 14 is a 1,200 gallon UST, which was free of liquid and sludge.
- 8:30 AM Dore begins uncover UST 14 for removal. The local fire department inspector was contacted, out of courtesy. Local fire department give its ok to proceed and will not be attending the removal.
- 9:00 AM UST 14 is uncovered and removed from ground. UST is transported to impermeable surface, located near UST removal location, for staging, cleaning and removal from site for destruction. UST 14 has significant holes and has been rendered unusable.
- 9:30 AM No further action is necessary by Amereco. UST 14 has been safely removed from excavation and poses no risk to human health and safety. Dore to further destroy and transport for disposal on later date. Amereco offsite.


Zachary Heine

UST Cert #UC20098078
Exp Date: 03/20/2013





Certificate Of Destruction

Project: Studebaker Area A Demolition Phase IV

Project Number: 109-032


Location of Tanks: Foundry Building (Bldg. #85)

County: St. Joseph

Certification Statement

Omni Source of South Bend, IN, a salvage facility, certifies that the underground storage tank (UST) listed below was destroyed on 1-26-12. Tank material was metal.

Tank #14: 1,200 gallon


Ryan Long

Omni Source

Date: 2/28/12